

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
**Monitoring Requirements Not Met for Atlantic Cape Community College**  
**Mays Landing Campus**

Our water system violated a drinking water test requirement during the year 2005. Even though this was not an emergency, as our students & staff, you have the right to know what happened, what you should do, and what we have done to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 3<sup>rd</sup> Quarter 2005 (July-September), we did not monitor or test for Trihalomethanes (THM4) and Haloacetic Acids (HAA5) as required and therefore cannot be sure of the quality of our drinking water during that time. Actual samples were taken and tested during the 4<sup>th</sup> Quarter 2005 (October-December). Both contaminants tested 0 ug/l; not present.

**What Should I do?**

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during 2005, how often we are supposed to sample for THM4/HAA5 and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

<b>Contaminant</b>	<b>Required Sampling Frequency</b>	<b>Number of samples taken</b>	<b>When all samples should have been taken</b>	<b>When samples were or will be taken</b>	<b>Test Results</b>
THM4/HAA5	1/Year	0	3 <sup>rd</sup> Q 2005	12/6/2005	0 ug/l

**What happened? What is being done?**

Due to a miscommunication between our water system operator and our testing laboratory, the Annual 2005 THM4/HAA5 monitoring was missed during the required calendar quarter. The missed sampling was discovered on 11/15/05 and the samples were collected and tested outside the required time period on 12/6/05. Both contaminants tested 0 ug/l.

The college's water system operator is: McGowan Well Water Compliance Mgt. LLC

For more information, please contact Linda McGowan at (973) 962.4432.